

ESYLUX GmbH | Post Box 1834 | 22908 Ahrensburg, Germany

To whom it may concern

ESYLUX GmbH  
An der Strusbek 40  
22926 Ahrensburg | Germany

t: +49 (0)4102 88880-0

info@esylux.com  
www.esylux.com

Managing Directors:  
Mareks Peters  
Helmi Kremser

Business register Lübeck District Court  
HRB 69 43 HL  
VAT: DE 249 684 359

your contact person	our e-mail	t:	date	page
Olaf Riebenstein	olaf.rienstein@esylux.com	+49 (0)4102 88880-4200	10/5/2020	1/1

UniCredit — HypoVereinsbank  
IBAN: DE34 2003 0000 0016 1750 36  
BIC: HYVEDEMM300

Hamburg Commercial Bank  
IBAN: DE84 2105 0000 1001 3496 18  
BIC: HSHNDEHHXXX

Deutsche Bank  
IBAN: DE07 2007 0000 0308 0066 00  
BIC: DEUTDEHHXXX

Kieler Volksbank eG  
IBAN: DE51 2109 0007 0010 3928 07  
BIC/SWIFT: GENODEF1KIL

## 10-A/16-A circuit breaker and maximum continual load

As stated in the installation instructions for our motion detectors and presence detectors, a 10-A circuit breaker is required so that the detector can limit the maximum continual load.

If the device is installed such that a maximum continual load of 10 A (2300 W/cos Phi = 1) is ensured during operation and in the event of a fault, a 16-A circuit breaker can be used instead of the 10-A variant.

Yours faithfully  
ESYLUX GmbH



p.p.  
Dr. Marc-Oliver von Maydell  
Engineering



p.p.  
Olaf Riebenstein  
Series Production