



## DECLARATION OF CONFORMITY

We Marshall-Tufflex Limited Castleham Industrial Estate, 55-65 Castleham Road,  
St. Leonards-on-Sea, East Sussex, TN38 9NU, United Kingdom

Declare under our sole responsibility that the products:  
**UNDERFLOOR RAISED FLOOR BOXES AND GROMMETS**

To which this Declaration relate are in conformity with the following standards and directives:

BS 7671:2018, Requirements for electrical installations, IET Wiring Regulations, Eighteenth edition

Low Voltage Directive (LVD) 2014/35/EU

BS EN 61534-22:2009, Powertrack systems Particular requirements for powertrack systems intended for on floor or under floor installation

BS EN 50085-2-2:2008, Cable trunking systems and cable ducting systems for electrical installations Particular requirements for cable trunking systems and cable ducting systems intended for mounting under floor, flush floor, or on floor

IEC 61084-1:2017, Cable trunking systems and cable ducting systems for electrical installations - Part 1: General requirements

IEC 61084-2-2:2017, Cable trunking systems and cable ducting systems for electrical installations - Part 2-2: Particular requirements - Cable trunking systems and cable ducting systems intended for mounting underfloor, flushfloor, or onfloor

BS 1363-2:1995+A4:2012, 13 A plugs, socket-outlets, adaptors and connection units Specification for 13 A switched and unswitched socket-outlets

Building Testing Limited, Load Testing of Electrical Floor Box Components, Report No. B2506/6781

A handwritten signature in black ink, appearing to read 'Jon Chamberlain'.



**Jon Chamberlain**  
**Managing Director**

Signed for and on behalf of Marshall-Tufflex Ltd

**Date: 09/11/2022**

Reg No: - 00374185-Registered in England & Wales, Registered Office: 55-65 Castleham Road, St. Leonards-on-Sea, East Sussex TN38 9NU. A member of the Marshall-Tufflex Group of Companies

**CERT000128 Issue 3**